

March 27, 2020

TO ALL PROSPECTIVE OFFERORS:

Subject: RFP: 20-PR-DPO-34

Addendum No.: 2

For: Odor Control Facilities Media Replacement - Labor

CLOSING DATE FOR RFP RESPONSES: APRIL 1, 2020

The subject RFP “Odor Control Facilities – Labor” was issued on March 5, 2020. This addendum is being issued to respond to formal questions submitted by prospective offerors and to provide links to access videos of a typical Odor Control Facility (OCF).

CHANGES TO THE RFP:

Answers to questions submitted by the March 20, 2020 deadline are as follows:

Question 1: Can we place media into the vessel without affecting any duct pipes?

Answer 1: We have panels on the Odor Control Facilities (OCF) which can be used to load and remove the spent media. It will not disturb any duct pipes.

Question 2: Will a TCLP on the spent media be provided or does a waste profile already exist for a disposal facility?

Answer 2: A TCLP (Toxicity Characteristic Leaching Procedure) will not be provided. The spent media should be disposed of legally and in an environmentally safe manner at an approved disposal facility, in accordance with local and federal laws.

Question 3: Regarding the pricing matrix, it is clear that Option 1 is for all six sites completed at the same time, while Option 3 is for each individual site completed at a time. However, it is not clear what Option 2 is. Can you please provide clarification on the Option 2 category of pricing?

Answer 3: In Attachment A, Scope of Work, Option 2, it states that media replacement will be completed in two phases within a 2-week period.
Phase 1: Sites 1995, 17 and 27 (3 sites to be completed at the same time)
Phase 2: Sites 46, 31 and 4 (3 sites to be completed at the same time)

Links to two videos of a typical OCF is provided. Should you have issues accessing the videos, please send an email to Angelia.Allison@dewater.com.

Video 1: Processing Room


https://dewater-my.sharepoint.com/:v:/p/asatyadev/EbbrYW71kKlGgbIMDMRXjW8BjHPQqm4whnrs1_uX2-ieuA?e=4Swlah

Video 2: Site 31 Electrical Room

<https://dewater-my.sharepoint.com/:v:/p/asatyadev/ER3AW6IQWItJgL0QGRf4z1wBmWmfsP0gcUb6N-O5q9yjsA?e=hLKCem>

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

All offerors responding to this solicitation must sign and complete the bottom portion of this page and return all documents to the email address listed in the RFP for submission. This addendum, together with your response package and any revisions or changes occasioned by this addendum, must be received prior the time set for receipt of bids.



Angelia Allison
Sr. Sourcing Specialist

FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM MAY BE CAUSE FOR REJECTION OF YOUR BID.

This addendum is acknowledged and is considered a part of RFP 20-PR-DPO-34, "Odor Control Media Replacement – Labor".

Signature of Authorized Representative

Title

Name of Firm

Date